

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 High Efficiency Three-Phase

Product code : 12846801

| | | | |
|-----------------------|-----------------|-----------------------------|------------------------|
| Frame | : 324/6T | Locked rotor time | : 43s (cold) 24s (hot) |
| Output | : 20 HP (15 kW) | Temperature rise | : 80 K |
| Poles | : 8 | Duty cycle | : Cont.(S1) |
| Frequency | : 60 Hz | Ambient temperature | : -20°C to +40°C |
| Rated voltage | : 575 V | Altitude | : 1000 m.a.s.l. |
| Rated current | : 22.7 A | Protection degree | : IP55 |
| L. R. Amperes | : 114 A | Cooling method | : IC411 - TEFC |
| LRC | : 5.0x(Code G) | Mounting | : F-1 |
| No load current | : 12.0 A | Rotation ¹ | : Both (CW and CCW) |
| Rated speed | : 880 rpm | Noise level ² | : 56.0 dB(A) |
| Slip | : 2.22 % | Starting method | : Direct On Line |
| Rated torque | : 119 ft.lb | Approx. weight ³ | : 506 lb |
| Locked rotor torque | : 200 % | | |
| Breakdown torque | : 220 % | | |
| Insulation class | : F | | |
| Service factor | : 1.25 | | |
| Moment of inertia (J) | : 9.79 sq.ft.lb | | |
| Design | : B | | |

| | | | | |
|----------------|------|------|------|------|
| Output | 25% | 50% | 75% | 100% |
| Efficiency (%) | 87.2 | 87.5 | 89.5 | 89.5 |
| Power Factor | 0.32 | 0.55 | 0.67 | 0.74 |

| | |
|------------------|-----------|
| Foundation loads | |
| Max. traction | : 754 lb |
| Max. compression | : 1261 lb |

| | Drive end | Non drive end |
|----------------------|------------------|---------------|
| Bearing type | : 6312 C3 | 6212 C3 |
| Sealing | : V'Ring | V'Ring |
| Lubrication interval | : 20000 h | 20000 h |
| Lubricant amount | : 21 g | 13 g |
| Lubricant type | Mobil Polyrex EM | |

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

| Rev. | Changes Summary | Performed | Checked | Date |
|--------------|-----------------|---------------|----------|------|
| | | | | |
| Performed by | | Page 1 / 1 | | |
| Checked by | | | | |
| Date | 28/03/2024 | | | |
| | | | Revision | |