DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Three Phase induction wotor - Squirer Cage									
Customer	:								
Product line	: W40 N Phase	IEMA Pre	emium Eff	iciency Thre	Product code : Catalog # :	14272927 12536OT3E404TS-W40G			
Frame Output Poles Frequency Rated voltage Rated current L. R. Amperes LRC No load current Rated speed Slip Rated torque Locked rotor torqu Breakdown torque Insulation class Service factor Moment of inertia of Design		: 404/5T : 125 HF : 2 : 60 Hz : 230/46 : 272/13 : 1850/9 : 6.8x(C : 72.0/30 : 3557 r : 1.19 % : 185 ft.I : 170 % : 260 % : F : 1.25 : 8.23 so	50 V 66 A 125 A ode G) 6.0 A pm		Locked rotor time Temperature rise Duty cycle Ambient temperature Altitude Protection degree Cooling method Mounting Rotation¹ Noise level² Starting method Approx. weight³	: 21s (cold) 12s (hot) : 80 K : Cont.(S1) : -20°C to +40°C : 1000 m.a.s.l. : IP23 : IC01 - ODP : F-1 : Both (CW and CCW) : 84.0 dB(A) : Direct On Line : 897 lb			
Output			75%	100%	Foundation loads	4004 !!			
Power Factor	90.3 90.3 92 0.57 0.59 0.	2.0 92.0 .79 0.80	92.9 92.9 0.86 0.86	94.7 94.7 0.88 0.88	Max. traction Max. compression	: 1091 lb : 1989 lb			
Bearing type Sealing Lubrication interva Lubricant amount	:		Drive 6314 Vithout Be 144	end 4 C3 earing Seal 18 h	Non drive end 6212 Z C3 Without Bearing Se 20000 h 13 g	eal			
Efficiency (%) Power Factor Bearing type Sealing Lubrication interva	92.8 90.2 93 90.3 90.3 93 0.57 0.59 0 0.55 0.48 0	3.0 91.9 2.0 92.0 0.79 0.80 0.77 0.70	94.1 92.9 92.9 92.9 0.86 0.86 0.84 0.80 <u>Drive</u> 6314 Vithout Be	994.1 94.7 9 94.7 94.7 6 0.88 0.88 0 0.86 0.84 end 4 C3 earing Seal 18 h	Max. traction Max. compression Non drive end 6212 Z C3 Without Bearing Se 20000 h				

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

` '					
Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	29/03/2024	1		1 / 1	