

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 NEMA Premium Efficiency Three-Phase

Product code : 11408296

Catalog # : 35012ET3G449T-W22

Frame : L447/9T
Output : 350 HP (260 kW)
Poles : 6
Frequency : 60 Hz
Rated voltage : 460 V
Rated current : 415 A
L. R. Amperes : 2864 A
LRC : 6.9x(Code H)
No load current : 160 A
Rated speed : 1190 rpm
Slip : 0.83 %
Rated torque : 1540 ft.lb
Locked rotor torque : 250 %
Breakdown torque : 270 %
Insulation class : F
Service factor : 1.15
Moment of inertia (J) : 278 sq.ft.lb
Design : A

Locked rotor time : 41s (cold) 23s (hot)
Temperature rise : 80 K
Duty cycle : Cont.(S1)
Ambient temperature : -20°C to +40°C
Altitude : 1000 m.a.s.l.
Protection degree : IP55
Cooling method : IC411 - TEFC
Mounting : F-1
Rotation¹ : Both (CW and CCW)
Noise level² : 71.0 dB(A)
Starting method : Direct On Line
Approx. weight³ : 3596 lb

Output	25%		50%		75%		100%	
Efficiency (%)	95.3	95.3	95.4	95.4	95.8	95.8	95.8	95.8
	95.3	94.5	95.4	95.0	95.8	95.4	95.8	95.8
Power Factor	0.42	0.44	0.66	0.68	0.77	0.78	0.82	0.83
	0.40	0.37	0.64	0.60	0.75	0.73	0.81	0.79

Foundation loads
Max. traction : 10929 lb
Max. compression : 14525 lb

Losses at normative operating points (speed;torque), in percentage of rated output power

Losses (%)	P1 (0,9;1,0)	5.1	5.1	5.1	5.1
	P2 (0,5;1,0)	3.8	3.8	3.8	3.8
	P3 (0,25;1,0)	3.4	3.4	3.4	3.4
	P4 (0,9;0,5)	2.9	2.9	2.9	2.9
	P5 (0,5;0,5)	1.9	1.9	1.9	1.9
	P6 (0,5;0,25)	1.4	1.4	1.4	1.4
	P7 (0,25;0,25)	0.8	0.8	0.8	0.8

		<u>Drive end</u>	<u>Non drive end</u>
Bearing type	:	6322 C3	6319 C3
Sealing	:	WSeal	WSeal
Lubrication interval	:	11000 h	13000 h
Lubricant amount	:	60 g	45 g
Lubricant type	:	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by		Page 1 / 1		
Checked by				
Date	28/03/2024			
		Revision		