

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 IEEE 841 NEMA Premium Efficiency Three-Phase Product code : 13148864
Catalog # : 30018ST3QIERB449T-W2

Frame	: 447/9T	Locked rotor time	: 28s (cold) 16s (hot)
Output	: 300 HP (220 kW)	Temperature rise	: 80 K
Poles	: 4	Duty cycle	: Cont.(S1)
Frequency	: 60 Hz	Ambient temperature	: -20°C to +40°C
Rated voltage	: 460 V	Altitude	: 1000 m.a.s.l.
Rated current	: 330 A	Protection degree	: IP56
L. R. Amperes	: 2145 A	Cooling method	: IC411 - TEFC
LRC	: 6.5x(Code G)	Mounting	: F-1
No load current	: 95.0 A	Rotation ¹	: Both (CW and CCW)
Rated speed	: 1780 rpm	Noise level ²	: 75.0 dB(A)
Slip	: 1.11 %	Starting method	: Direct On Line
Rated torque	: 885 ft.lb	Approx. weight ³	: 2984 lb
Locked rotor torque	: 229 %		
Breakdown torque	: 229 %		
Insulation class	: F		
Service factor	: 1.15		
Moment of inertia (J)	: 89.6 sq.ft.lb		
Design	: B		

Output	25%	50%	75%	100%	Foundation loads					
Efficiency (%)	95.7	95.5	95.8	95.8	96.2	95.8	96.2	96.0	Max. traction	: 4871 lb
	95.8	94.9	95.8	95.4	96.2	95.8	96.0	96.2		
Power Factor	0.53	0.54	0.77	0.78	0.84	0.84	0.87	0.87	Max. compression	: 7855 lb
	0.50	0.48	0.75	0.73	0.83	0.82	0.87	0.86		

Losses at normative operating points (speed;torque), in percentage of rated output power

Losses (%)	P1 (0,9;1,0)	4.2	4.2	4.2	4.2
	P2 (0,5;1,0)	3.6	3.6	3.6	3.6
	P3 (0,25;1,0)	3.3	3.3	3.3	3.3
	P4 (0,9;0,5)	2.0	2.0	2.0	2.0
	P5 (0,5;0,5)	1.4	1.4	1.4	1.4
	P6 (0,5;0,25)	0.9	0.9	0.9	0.9
	P7 (0,25;0,25)	0.6	0.6	0.6	0.6

		Drive end	Non drive end
Bearing type	:	NU-322 C3	6319 C3
Sealing	:	Inpro/Seal	Inpro/Seal
Lubrication interval	:	4000 h	8000 h
Lubricant amount	:	60 g	45 g
Lubricant type	:	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	25/03/2024			
			Page	Revision
			1 / 1	