

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 IEEE 841 NEMA Premium Efficiency Three-Phase Product code : 16687098
Catalog # : 00718ST3QAP213T-W22

Frame	: 213/5T	Locked rotor time	: 36s (cold) 20s (hot)
Output	: 7.5 HP (5.5 kW)	Temperature rise	: 80 K
Poles	: 4	Duty cycle	: Cont.(S1)
Frequency	: 60 Hz	Ambient temperature	: -20°C to +40°C
Rated voltage	: 460 V	Altitude	: 1000 m.a.s.l.
Rated current	: 9.18 A	Protection degree	: IP56
L. R. Amperes	: 65.2 A	Cooling method	: IC411 - TEFC
LRC	: 7.1x(Code H)	Mounting	: W-8
No load current	: 4.20 A	Rotation ¹	: Both (CW and CCW)
Rated speed	: 1765 rpm	Noise level ²	: 58.0 dB(A)
Slip	: 1.94 %	Starting method	: Direct On Line
Rated torque	: 22.3 ft.lb	Approx. weight ³	: 181 lb
Locked rotor torque	: 220 %		
Breakdown torque	: 310 %		
Insulation class	: F		
Service factor	: 1.15		
Moment of inertia (J)	: 1.34 sq.ft.lb		
Design	: B		

Output	25%	50%	75%	100%	Foundation loads					
Efficiency (%)	88.6	89.2	89.5	89.5	91.0	89.5	91.7	89.6	Max. traction	: 349 lb
	89.2	89.3	89.5	89.5	90.2	90.2	90.2	90.2		
Power Factor	0.40	0.47	0.66	0.72	0.76	0.81	0.82	0.85	Max. compression	: 530 lb
	0.43	0.40	0.69	0.66	0.78	0.76	0.83	0.82		

Losses at normative operating points (speed;torque), in percentage of rated output power

Losses (%)	P1 (0,9;1,0)	8.8	8.8	8.8	8.8
	P2 (0,5;1,0)	7.0	7.0	7.0	7.0
	P3 (0,25;1,0)	6.5	6.5	6.5	6.5
	P4 (0,9;0,5)	4.9	4.9	4.9	4.9
	P5 (0,5;0,5)	3.3	3.3	3.3	3.3
	P6 (0,5;0,25)	2.4	2.4	2.4	2.4
	P7 (0,25;0,25)	1.6	1.6	1.6	1.6

		Drive end	Non drive end
Bearing type	:	NU-308 C3	6207 C3
Sealing	:	Inpro/Seal	Inpro/Seal
Lubrication interval	:	16000 h	20000 h
Lubricant amount	:	11 g	7 g
Lubricant type	:	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	26/03/2024			
			Page	Revision
			1 / 1	