## **DATA SHEET**

## Three Phase Induction Motor - Squirrel Cage



Customer Product line : W40 NEMA Premium Efficiency Three-Product code: 11601950 Catalog #: 70036OT3G5010S-RF Frame : 5010/11TS Locked rotor time : 21s (cold) 12s (hot) Output : 700 HP (515 kW) Temperature rise : 80 K Poles Duty cycle : Cont.(S1) : -20°C to +40°C Frequency : 60 Hz Ambient temperature Rated voltage : 460 V : 1000 m.a.s.l. Altitude : 760 A Rated current Protection degree : IP23 L. R. Amperes : 6080 A Cooling method : IC01 - ODP LRC : 8.0x(Code G) Mounting : F-1 No load current : 205 A Rotation<sup>1</sup> : Both (CW and CCW) Rated speed : 3578 rpm Noise level<sup>2</sup> : 86.0 dB(A) Starting method Slip : 0.61 % : Direct On Line Rated torque : 1030 ft.lb Approx. weight<sup>3</sup> : 4212 lb Locked rotor torque : 200 % Breakdown torque : 280 % Insulation class : F Service factor : 1.15 Moment of inertia (J) : 78.5 sq.ft.lb 25% 100% 50% 75% Foundation loads Output Efficiency (%) 0.000 96.0 96.5 96.6 Max. traction Power Factor 0.00 0.77 0.85 0.88 Max. compression Drive end Non drive end Bearing type 6314 C4 6314 C4 Without Bearing Seal Sealing

1200 h Lubricant amount 10 g Lubricant type

Without Bearing Seal 1200 h

10 g

Mobil Polyrex EM

Notes:

Lubrication interval

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.

(4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.		Changes Summary	Performed	Checked	Date
Performed by					
Checked by				Page	Revision
Date	26/03/2024			1/2	

## DATA SHEET

	П
ш	Ш

Three Phase Induction Motor - Squirrel Cage									
Customer :									
\/-lt 440 407	7/000 040 V	Space heater infor	Space heater information						
Voltage: 110-127	7/200-240 V								
Rev.		Changes Summary	Performed	Checked	Date				
Performed by									
Checked by				Page	Revision				
Date	26/03/2024			2/2					