

# DATA SHEET

## Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : Close Coupled Pump NEMA Premium  
Efficiency Three-Phase

Product code : 11083253

Catalog # : 02018OT3E256JP

Frame : 256JP  
Output : 20 HP (15 kW)  
Poles : 4  
Frequency : 60 Hz  
Rated voltage : 230/460 V  
Rated current : 49.4/24.7 A  
L. R. Amperes : 311/156 A  
LRC : 6.3x(Code G)  
No load current : 24.0/12.0 A  
Rated speed : 1770 rpm  
Slip : 1.67 %  
Rated torque : 59.3 ft.lb  
Locked rotor torque : 260 %  
Breakdown torque : 280 %  
Insulation class : F  
Service factor : 1.15  
Moment of inertia (J) : 2.62 sq.ft.lb  
Design : B

Locked rotor time : 21s (cold) 12s (hot)  
Temperature rise : 80 K  
Duty cycle : Cont.(S1)  
Ambient temperature : -20°C to +40°C  
Altitude : 1000 m.a.s.l.  
Protection degree : IP23  
Cooling method : IC01 - ODP  
Mounting : F-1  
Rotation<sup>1</sup> : Both (CW and CCW)  
Noise level<sup>2</sup> : 60.0 dB(A)  
Starting method : Direct On Line  
Approx. weight<sup>3</sup> : 284 lb

Output	25%		50%		75%		100%	
Efficiency (%)	91.5	86.4	91.7	87.6	93.0	90.4	93.0	91.4
	85.8	85.3	87.1	86.7	90.4	90.4	91.5	91.6
	89.4	89.4	90.2	90.2	91.0	91.0	91.7	91.7
	89.4		90.2		91.0		91.7	
Power Factor	0.37	0.35	0.63	0.59	0.72	0.72	0.82	0.80
	0.31	0.28	0.54	0.49	0.67	0.62	0.76	0.71
	0.43	0.39	0.68	0.63	0.80	0.76	0.84	0.81
	0.34		0.58		0.72		0.78	

Foundation loads  
Max. traction : 955 lb  
  
Max. compression : 1239 lb

		<u>Drive end</u>	<u>Non drive end</u>
Bearing type	:	6309 Z C3	6209 Z C3
Sealing	:	Without Bearing Seal	Without Bearing Seal
Lubrication interval	:	20000 h	20000 h
Lubricant amount	:	13 g	9 g
Lubricant type	:	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	28/03/2024			

Page 1 / 1  
Revision