

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W22 Tru-Metric IE4 Three-Phase

Product code :

17302706

Catalog # :

13212EG3Y315L-W22

Frame : 315L
Output : 175 HP (132 kW)
Poles : 6
Frequency : 50 Hz
Rated voltage : 380 V
Rated current : 249 A
L. R. Amperes : 1693 A
LRC : 6.8
No load current : 95.0 A
Rated speed : 990 rpm
Slip : 1.00 %
Rated torque : 928 ft.lb
Locked rotor torque : 220 %
Breakdown torque : 229 %
Insulation class : F
Service factor : 1.00
Moment of inertia (J) : 227 sq.ft.lb
Design : NE

Locked rotor time : 79s (cold) 44s (hot)
Temperature rise : 80 K
Duty cycle : S1
Ambient temperature : -20°C to +40°C
Altitude : 1000 m.a.s.l.
Protection degree : IP55
Cooling method : IC411 - TEFC
Mounting : B3L(E)
Rotation¹ : Both (CW and CCW)
Noise level² : 68.0 dB(A)
Starting method : Direct On Line
Approx. weight³ : 3010 lb

Output	25%	50%	75%	100%				
Efficiency (%)	0.000	95.4	95.2	95.8	95.9	96.0	96.0	
	0.000	95.0	95.0	95.8	95.9	96.0	96.2	
	0.000							
	0.000							
Power Factor	0.00	0.00	0.70	0.66	0.80	0.78	0.84	0.81
	0.00	0.00	0.64	0.65	0.76	0.76	0.81	0.81

Foundation loads
Max. traction : 4049 lb

Max. compression : 7059 lb

Losses at normative operating points (speed;torque), in percentage of rated output power

Losses (%)	P1 (0,9;1,0)	4.2	4.2	4.2	4.1
	P2 (0,5;1,0)	3.3	3.3	3.3	3.2
	P3 (0,25;1,0)	2.9	2.9	2.9	2.8
	P4 (0,9;0,5)	2.2	2.2	2.2	2.1
	P5 (0,5;0,5)	1.5	1.5	1.5	1.4
	P6 (0,5;0,25)	1.0	1.0	1.0	1.0
	P7 (0,25;0,25)	0.7	0.7	0.7	0.6

		<u>Drive end</u>	<u>Non drive end</u>
Bearing type	:	6319 C3	6316 C3
Sealing	:	WSeal	WSeal
Lubrication interval	:	13000 h	16000 h
Lubricant amount	:	45 g	34 g
Lubricant type	:	Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by				
Checked by				
Date	26/03/2024			

Page 1 / 1
Revision