

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Product line : W60 Standard Efficiency Three-Phase Product code : 16166515

Frame	: 5010/11	Locked rotor time	: 25s (cold) 14s (hot)
Output	: 750 HP (560 kW)	Temperature rise	: 80 K
Poles	: 2	Duty cycle	: Cont.(S1)
Frequency	: 60 Hz	Ambient temperature	: -20°C to +40°C
Rated voltage	: 460 V	Altitude	: 1000 m.a.s.l.
Rated current	: 821 A	Protection degree	: IP24
L. R. Amperes	: 4924 A	Mounting	: F-1
LRC	: 6.0x(Code F)	Rotation ¹	: CW
No load current	: 124 A	Noise level ²	: 85.0 dB(A)
Rated speed	: 3560 rpm	Starting method	: Direct On Line
Slip	: 1.11 %	Approx. weight ³	: 4366 lb
Rated torque	: 1110 ft.lb		
Locked rotor torque	: 60 %		
Breakdown torque	: 200 %		
Insulation class	: F		
Service factor	: 1.00		
Moment of inertia (J)	: 80.7 sq.ft.lb		

Output	25%	50%	75%	100%	Foundation loads
Efficiency (%)	95.0	95.2	96.2	96.2	Max. traction
Power Factor	0.67	0.84	0.88	0.89	Max. compression

	Drive end	Non drive end
Bearing type	: 6218 C4	: 6218 C4
Sealing	: Without Bearing Seal	: Without Bearing Seal
Lubrication interval	: 12045 h	: 12045 h
Lubricant amount	: 24 g	: 24 g
Lubricant type	: Mobil Polyrex EM	

Notes:

This revision replaces and cancel the previous one, which must be eliminated.

- (1) Looking the motor from the shaft end.
- (2) Measured at 1m and with tolerance of +3dB(A).
- (3) Approximate weight subject to changes after manufacturing process.
- (4) At 100% of full load.

These are average values based on tests with sinusoidal power supply, subject to the tolerances stipulated in NEMA MG-1.

Rev.	Changes Summary	Performed	Checked	Date
Performed by		Page 1 / 2 Revision		
Checked by				
Date	27/03/2024			

DATA SHEET

Three Phase Induction Motor - Squirrel Cage



Customer :

Thermal protection

ID	Application	Type	Quantity	Sensing Temperature
1	Winding	PT100 - 3 wires	2 x Phase	-
2	DE bearing	PT100 - 3 wires	1 x Bearing	-
3	NDE bearing	PT100 - 3 wires	1 x Bearing	-

Space heater information

Voltage: 110-127/200-240 V

Rev.	Changes Summary		Performed	Checked	Date
Performed by				Page 2 / 2Revision	
Checked by					
Date	27/03/2024				